

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing
A.B.N 43 006 014 106
1st Floor, 191 Racecourse Road, Flemington, Victoria 3031
P.O Box 240, North Melbourne, Victoria 3051
Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

Client : Bru Textiles NV
Satenrozen 2A
B-2550 Kontich
Belgium

Test Number : 16-000366
Issue Date : 15/02/2016
Print Date : 16/02/2016

Sample Description Clients Ref : "FR One - Genii - Chenille"
Woven fabric - Chenille yarns
Colour : Multi
End Use : Curtains, Accessories, Upholstery, Bed Covers
Nominal Composition : 100% Polyester, inherent FR
Nominal Mass per Unit Area/Density : 395g/m²
Nominal Thickness : Approx: 1.5mm

AS 1530.2-1993

Methods for Fire Tests on Building Materials, Components and Structures. Part 2: Test for Flammability of Materials

Date Tested		15/02/2016
Flammability Index		3
	Length	Width
Spread Factor	2	0
Heat Factor	1	1
Maximum height (d)		
Mean	4.1	2.9
Coefficient of Variation	17.0	32.1 %
Heat (a)		
Mean	4.2	3.4 °C.min
Coefficient of Variation	53.6	47.3 %
Number of Specimens Tested	9	9
Observation	Smoking and melting of specimens.	

48668

9916

Page 1 of 2

© Australian Wool testing Authority Ltd
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025

- Chemical Testing
- Mechanical Testing
- Performance & Approvals Testing

: Accreditation No.

983

: Accreditation No.

985

: Accreditation No. 1356



Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by

MICHAEL A. JACKSON B.Sc. (Hons)
MANAGING DIRECTOR

APPROVED SIGNATORY

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing

A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031

P.O Box 240, North Melbourne, Victoria 3051

Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

Client : Bru Textiles NV
Satenrozen 2A
B-2550 Kontich
Belgium

Test Number : 16-000366
Issue Date : 15/02/2016
Print Date : 16/02/2016

These test results relate only to the behaviour of the test specimens of the material under the particular conditions of the test, and they are not intended to be the sole criterion for assessing the potential fire hazard of the material in use.

48668

9916

Page 2 of 2

© Australian Wool testing Authority Ltd
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025

- Chemical Testing
- Mechanical Testing
- Performance & Approvals Testing

: Accreditation No. 983
: Accreditation No. 985
: Accreditation No. 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by



APPROVED SIGNATORY

MICHAEL A. JACKSON B.Sc. (Hons)
MANAGING DIRECTOR