

CERTIFICATE OF TESTING

For the Account Of: Bru Textiles
Satenrozen 2a
B2550 Kontich
Belgium
Contact: Brigitte Gyselincx

Client's Identification: FR- One Jaba

TEST PERFORMED NY / NJ Port Authority Specifications Governing the Flammability of Drapery and Curtain Materials in Unsprinkled Areas (Appendix A) – 2010
[FAR 25.853(a) Appendix F, as revised February 2, 1995 – 12 second vertical method]

TEST RESULTS

Specimen	Afterflame (s)	Char Length (in)
1	0	4.8
2	0	5.4
3	0	5.1
Average Warp	0	5.1
4	0	4.4
5	0	5.0
6	0	5.0
Average Fill	0	4.8

Tested:

- Initially
- After Laundering
- After Dry Cleaning

NOTES

Test Conditions: 70 ±2°F, 65 ±2% Relative Humidity

ACCEPTANCE CRITERIA


1. Average Burn Length cannot exceed **8 inches** maximum average.
2. Average Flame Time after removal of the flame source may not exceed **5 seconds**.

CONCLUSION

Based on the above Results and Acceptance Criteria, the item tested:

- Complies
- Does Not Comply

CERTIFICATION I certify that the above results were obtained after testing specimen in accordance with the procedures and equipment specified by the standard stated above.


Authorized Signature CR